

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-1076:165 Page 1 of 1

CATEGORY: Power Unit

LISTEE: Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721
Contact: Terrill Garland (508) 881-2000

DESIGN: Model 297106 power supply/battery charger with Model *297107 enclosure. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120/240VAC Primary, 24 VDC Secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product identification and UL label.

APPROVAL: Listed as a power supply/battery charger for use with any separately listed compatible fire alarm equipment.

*Corrected 08-30-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 30, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager